




SEIRP Technical Conference

Integrating a Proposed Hydro Project into a 3 (5) City System April 20 , 2011

Eric Wolfe-Director of Special Projects
(907) 228-2281

Southeast Alaska Power Agency




KPU Diesel 12 MW
KPU Hydro 6.1 MW

KTN



1.5



0 MW

Blind Slough
1.1 MW




PSG

6

WRG



12




13.5 MW

SEAPA Generation

1.5





Power
1-100 Watt bulb

Energy
100 Watts for 24 hrs= 2400 Wh- energy
100 Watts for 24 hrs = 2.4 kWh (kiloWatt hours)
100 Watts for 24 hours = .0024 MWh (MegaWatt hr)

10,000 X



Power
10,000 bulbs = 1 MW

Energy
10, 000 bulbs for 24 hours = 24 MWh
or
417 100 W bulbs for 24 hrs = 1 MWh



1 Tye Turbine = 12.5 MW
Tye Plant (2 turbines) \cong 6 Locomotives



Three of the new 6,000 hp US diesel-electric locomotives


1 Locomotive = 6000 hp or 4.4 MW
3 Locomotives = 13.2 MW


In Ketchikan 1 MW can serve 800 homes using 900 kWh/month flat demand rate. In the winter 1 MW can meet the peak demands of approximately 650 homes . In summer 1 MW can serve approximately 1000 homes.

PSG – WRG – KTN Daily Loads - how they vary hour by hour


The morning peak was 43 MW for the hour 8am to 9am

The total load for the day is the area under the curve (MW x hr) = 936 MWh





365days



If you add up the area under each days curve, and sum all the days of the year, this is the regions total energy demand in MWh.

Table of Daily Energy

1-Jan	795.6
1-May	400
9-Aug	600
20-Dec	936
31-Dec	912
Total	252,737




Southeast Alaska Power Agency

2010 Actual Load and Resource Values

Table of PSG-WRG-KTN Loads and Resources	MWh
PSG + WRG + KTN Load + Distribution Losses	252,737
Transmission Losses	5,406
Total Load	258,143
Tyee spilled energy	42,800
Swan Lake Spilled Energy	6,500
Total Spilled Energy	49,300
Total Hydro Capability for 2010	307,443


252,737 MWh



Region is long by nearly
50,000 MW-hr;
Tyee spilled for 5 months!
Swan Lake spilled for 1
month

All hydro and diesel
generation inside the
brown region, diesel in
2010 was limited to
maintenance efforts

Load Resource Balance for 2010



Southeast Alaska Power Agency

Too big a water year is problematic!


The majority of spilled energy of 2010 occurred from late October through November. While SEAPA allows for storage increases to occur at Swan Lake and Tyee during this period, we don't assume extremely high events will occur. These events are problematic for two other reasons.

1) Loads decrease because of the warm weather, and loads decrease because these strong storms cause outages. It's hard to ramp up hydro units to avoid spill if your line is out.


2) Our member utilities dislike spill just as much as we do. Their generation increases which further reduces loads to SEAPA.



That's right, in one year we go from way long to significantly short. In SE Alaska a 100% hydro system is feast or famine. As we discuss resource balance today, KPU's Bailey Plant is generating with diesel engines! February loads were an astounding 46% above February 2010 Loads, Jan, March and April were also significantly above our projections which included provisions for the boiler conversion program. Cold weather has reduced inflows to near zero, storage is seriously depleted. Diesel generation (9-14 MW) is expected to last for 2-4 weeks depending on what else ?.....WEATHER.




Historical Inflows: Tye Reservoir



Huge annual fluctuations in fuel lead to large fluctuations in hydro output.


Swan Elevations 2010 and Present

Spill at 330.0 ft ; Minimum at 271.5 ft




Tyee Elevations 2010 and Present


Spill (nominal) at 1390 ft ; Minimum at 1250 ft,
 Ops Plan first warning, May 10th, elevation 1305 ft.



This is exactly why we are here today, a short year after completion of a new project makes you think of planning! What is the long term load and resource balance for the Region?




- 2012 to 2015- use historical average hydro generation
- 2015 Whitman 800 KW, next near full project complete
- 2018 Kake Intertie commissioned, Metlakatla on a future analysis
- 2020 Project A commissioned



Before Project A can be estimated as a reliable contribution, the FERC application is reviewed. As the majority provider to our member communities we have a responsibility to verify the proposed project will be financially viable.

Are you sure that project will integrate into the system and provide the stated energy?

- 1) Verify hydrology
- 2) Verify hydraulics
- 3) Plant operation proposal consistent with system operation?, will it integrate well or will significant inefficiencies result



Verify basin hydrology

- Basin productivity reasonable- cfs/sq. mi consistent with like basins?
- Stream gage information available? Data intact or sporadic? If sporadic what were correcting assumptions?
- Stream gage corrected back to reservoir using appropriate methods for elevation change and tributary areas





Verify project hydraulics

- Flow rates and net head consistent, tunnels, penstock sized appropriately?
- Is there daily, weekly, monthly or seasonal storage?
- Plant output restricted by ramp rates?
- Plant output restricted by reservoir limits or reservoir rate change limits?
- How were annual and monthly capacity and energy values derived?
 - Never Average inflow**, you won't get average generation
 - See tail end of presentation for details

A word concerning Storage

	Storage	Plant Pwr	Plant Hydr	# days
Project	Ac ft	Cap MW	Cap cfs	storage
KPU Ktn Lks	13,600	4.2	127	54
KPU Silvis	38,000	2.5	80	241
KPU BVR Falls	8,052	7	87	47
SEAPA Swan lake	86,000	22	921	64
SEAPA Tye	52,400	24	200	132
PMP&L Blind Sl.	4,875	2	16	152
Mahoney Lake	4,000	9.6	58	35
Cascade Swan Lake	3,474	70	670	3
Ruth	2,200	20.1	152	7
Ruth with Dam	3,900	40	305	6

High altitude reservoirs require storage to assist with winter loads!
 High altitude reservoirs with little storage are prone to spill in summer when loads are low



Which project do you think will waste less water?

Monday, December 20, 2010




Ramp rate restrictions add more burden to hourly load following efforts!

Inputs

- Add new plant to existing system
- Hourly Loads
- Daily Avg. Inflow sequence for a year
- Reservoir Start
- Spin Reserve Reqt.s.
- Buss limitations
- Reservoir limits


Outputs

- System
- Diesel Gen
- Hydro Gen by plant
- Spill by plant
- End Reservoir Levels



**Proposed Project
70,000 MWh, \$110 M**


**Actual Expectation
50,000 MWh, \$140M**



**Project as proposed as
stand alone benefit in
FERC Application**

**Actual dispatched energy
to system and updated
costs. This project gets
evaluated in Dave's
Finance Model**

Now you can add the 50,000 MWh of system generation, you have high confidence it will be produced when needed and sold to help pay the bankers!



The Senate set a vote on the short-

Continued on page 6

Sitka Asked to Cool It On Use of Electricity

By SHANNON HAUGLAND
Sentinel Staff Writer

ating system, says the present situation is red, indicating the most critical need

Summary


- This is a process, not a one-off solution, IRPs are repeated every 2-3 years
- Any solution will include diesel, SE AK is too volatile
 - Unless the project is way over-sized (Tye), those days are over
- Demand Side management hasn't been discussed, but is a real consideration
- Diesel costs could be lowered through use of pooling the reservoirs, buying bulk and employing a hedge manager
- Hard to Hide a mistake (Kevin Harper), another words our small populations can't support an expensive under-utilized project diesel costs


down or the breaker off," Andy Eggen, acting utility director, said in a news release. "Turn on a non-electric heat source during cold weather."

The electric department, which uses a red-yellow-green traffic light symbol



Eggen said switching to non-electric heat in that part of town is critical during cold weather (32 degrees and below), especially if there is an outage. If HPR experiences a cold weather out-

Why you can't average river gages to get average generation





If you replace the last large inflow with a really large inflow, the average must move, but the median stays the same. Plants with small to moderate storage sized for average spill. If you make the plant large enough to generate the average you will not recapture your investment..ever



Historical Inflows: Tye Reservoir

